



STATE OF TENNESSEE
DEPARTMENT OF COMMERCE AND INSURANCE
DIVISION OF FIRE PREVENTION
ELECTRICAL, RESIDENTIAL AND MARINA SECTION
500 JAMES ROBERTSON PARKWAY
NASHVILLE, TENNESSEE 37243-1160
TELEPHONE: (615) 741-7170 FAX: (615) 253-4895

To Whom It May Concern:

Due to the flooding experienced in Tennessee in the past weeks, a cursory electrical safety check was conducted at this location by the Department of Commerce and Insurance, Division of Fire Prevention ("Division"). Employees of the Division determined that the water level did not reach a level on the electrical equipment at this location that would require follow up inspections.

While the Division's cursory electrical safety check did not reveal any safety issues relating to the flooding at or near this location, the safety check was not fully comprehensive, and the Division cannot guarantee that no damage resulted from the flooding at or near this location.

Pursuant to National Electric Code 110.11 and 110.12(B) (2017 edition), receptacles and switches that have been submerged must be replaced. Ground-fault circuit interrupter ("GFCI") receptacles that have been submerged may not operate correctly and may lead to electrocution.

If you have any questions, please contact Joel Crofton, Electrical Inspector Lead, at (731) 513-3040 or Dwyot Thornton, Electrical Inspector Lead, at (615) 347-8173.

Sincerely,

Michael Morelli
Director of Fire Prevention Inspections, Permits & Licensing
Division of Fire Prevention/State Fire Marshal's Office
Department of Commerce and Insurance