


LEXINGTON ELECTRIC SYSTEM

MOBILE HOME METER POLE

GENERAL ARRANGEMENT



:: NOTES ::

- ① *Mobile Home Meter Pole - Minimum 18' long Round Pole with minimum 4" diameter top --*
Additional height may be required to maintain required minimum clearance over roof or to maintain proper clearance if crossing driveways.
- ② *Meter to face 90 Degrees from Mobile Home as shown in this sketch -- Meter base supplied by Lexington Electric System and can be picked up at the Lexington Office or Warehouse*
- ③ *If guying is necessary for the service wires, the owner is required to install guys for this pole.*

All wiring must meet the State of Tennessee Wiring Code and the National Electric Code (N.E.C.). LES will not connect to Meter Pole until approved by the Tennessee State Deputy Inspector.