

**LEXINGTON ELECTRIC SYSTEM
RESIDENTIAL OVERHEAD SERVICE
GENERAL ARRANGEMENT**

ALL NEW OVERHEAD
MAST ARE REQUIRED
TO HAVE AN INSULATED
SERVICE WIRE ATTACHMENT
DEVICE INSTALLED BY
ELECTRICIAN BEFORE
LES CONNECTS SERVICE
EFFECTIVE AS OF 12-1-2018

12' MINIMUM FROM GROUND

:: NOTES ::

- ① Meter Base should be installed between 5'-6" and 6' from final grade. Meter base supplied by Lexington Electric System and can be picked up at the LES Warehouse by appointment
- ② MINIMUM CLEARANCES ABOVE GROUND:
 - 12 FEET ABOVE PRIVATE PROPERTY (PEDESTRIAN AREA)
 - 16 FEET ABOVE DRIVEWAYS
 - 18 FEET ABOVE PUBLIC STREET OR ROADWAY

METER BASE
SUPPLIED BY
LES

5'-6" ABOVE FINISH GRADE

All wiring must meet the State of Tennessee Wiring Code and the National Electric Code (N.E.C.). LES will not connect to Meter Base until approved by the Tennessee State Deputy Inspector.